BERRIEW COMMUNITY COUNCIL / CYNGOR CYMUNED ABERRIW

FIRE RISK MANAGEMENT REPORT 2017/18

PUBLIC CONVENIENCES, BERRIEW, WELSHPOOL, POWYS, SY21 8PQ

People at Risk	Evaluate potential consequences/ Hazard	Internal control (Appropriate measure to avoid, reduce or cancel the risk or its consequence)	Assessment of Risk with Internal Control Measures in place
Premises only occupied by public when using facilities or when cleaning etc. is in progress.	Risk of Fire from: Electrical fault Cigarettes Matches Combustible items: Litter in bins Plastic Toilet roll dispensers Plastic hand driers	 Waste bins to be regularly emptied Fixed electrics to be inspected every 3 years by competent person (M D Prior 19.03.14) Cleaning equipment to be stored in locked metal cabinet No smoking signs Fire Risk Assessment to be reviewed annually Fire Alarms are not considered necessary 	Considered Low Risk with controls in place